



[]

company
POLOPLAST GMBH & CO KG

Poloplast-Straße 1
A-4060 Leonding

[]

your sign
Erwin Mayrbäurl

your message
11th April 2013

our sign
KU24593

executive officer
Harald Vock

date
14th May 2013

concern: Halogen-free POLO KAL NG Multilayer-piping system

Dear Mr Mayrbäurl,

We as an external monitoring test institute can approve the use of the following materials for the production of the multilayer pipingsystem POLO-KAL NG (Manufacturer Fa. Poloplast Werk A-4060 Leonding):

Pipes

Inner and outer layer:

PP-Copolymer + masterbatch

Middle layer:

PP-Copolymer + mineral additive (untreated talcum)

Fittings

PP-Copolymer + masterbatch+ mineral additive (treated chalk)

According to their datasheets the chemical composition of each of these materials contains halogen-free components. However, impurities caused by other components which contain halogens, cannot be completely excluded.

Kind regards

Prof. Dipl.- Ing. Andreas Schmidt
(Head of department)